

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for March'26

Issue Date: 28th March 2025

Issue Time: 1700 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Control area | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Approved GNA (MW) | Margin for T-GNA (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|--------------------------|--------------|--|--------------------|-------------------------------------|-------------------|-----------------------|-------------------------------------|----------|
| 1st to 31st March'26 | 00-24 | DNHDDPDCL | 1375 | 30 | 1345 | 1206 | 139 | | |
| | 00-24 | DNH | 475 | 10 | 465 | 384 | 81 | | |
| | 00-24 | DD | 900 | 20 | 880 | 822 | 58 | | |
| Limiting Constraints | | | DNH: N-1 contingency of 220 kV Kala-Khadoli D/C | | | | | | |
| | | | DD: N-1 contingency of 220 kV Magarwada (PG)-Ringanwada (DD) D/C | | | | | | |

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

Import of DNHDDPDCL Transfer Capability for March'26

| Issue Date: 28th March 2025 | Date of Revision | Period of Revision | Reason for Revision |
|--|-----------------------------|-------------------------------|----------------------------|
| | | | |