

**National Load Despatch Centre**  
**Import of DNHDDPDCL Transfer Capability for Sept 2025**

Issue Date: 28th Oct 2024

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Control area	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
01st Oct-31st Oct'25	00-24	DNHDDPDCL	1310	25	1285	1206	79	-	
	00-24	DNH	840	15	825	822	3	-	
	00-24	DD	470	10	460	384	76	-	
<b>Limiting Constraints</b>			DNH: N-1 contingency of 220 kV Kala-Khadoli D/C						
			DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c						

**\*\*This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

**Import of DNHDDPDCL Transfer Capability for Oct 2025**

<b>Issue Date: 28th Oct 2024</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>