

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for Sept 2025**

Issue Date: 28-09-2024

Issue Time: 17:00

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
01st Sept 2025 to 30th Sept 2025	00-24	10300	500	9800	5497	4303	500	
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220KV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

### Import of Punjab Transfer Capability for August 2025

Revision No	Date of Revision	Period of Revision	Reason for Revision