

National Load Despatch Centre
Export of DVC Transfer Capability for January 2022

Issue Date: 26th December 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2022 to 31st January 2022	00-24	2840	50	2790	2660.69	129		In normal case(not extreme import or export),if 220 KV Waria-DStps-Parulia(DVC) d/c is in loop,flow of 220 KV DSTPS to WArea d/c may reach 190 MW each,which is a constraint
Limiting Constraints		Limited BY LGBR in extreme cases.For normal case,plz see comments.						