

National Load Despatch Centre
Import of DVC Transfer Capability for November 2021

Issue Date: 26th October 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2021 to 30th November 2021	00-24	1458.8	61	1397.8	653.84	744		
Limiting Constraints		1. With Both 220kV DSTPS-DTPS D/C & 220kV DSTPS-Parulia D/C connected and without DSTPS units & MTPS#6, the drawl from 220kV Parulia PG becomes ~ 145MW each. 2. The Line Loading through 132kV MHS-Jamtara Tie is ~ 90MW towards Jamtara.						