

**POWER SYSTEM OPERATION CORPORATION LIMITED**  
**NATIONAL LOAD DESPATCH CENTRE**  
**URGENT MARKET INFORMATION**

Date of Issue: 25-May-2012

Time of Issue: 18:00 Hrs

The TTC/ATC of ER-NER corridor is revised due to the S/D of the following elements:

1. 400kV Balipara- Bongaigaon II- 08:00 hrs of 27/05/2012 to 17:00 hrs of 29/05/2012 on daily basis.
2. 400kV Malda-Purnea S/D/C- 07:00 hrs of 28/05/2012 to 16:00 hrs of 21/06/2012 on continuous basis.

**1. For 27/05/2012**

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-08:00	590	200	35	355
	08:00-17:00	350	200	35	115
	17:00-24:00	590	200	35	355
NER→ER	00:00-08:00	570	0	100	470
	08:00-17:00	110	0	100	10
	17:00-24:00	570	0	100	470

**2. For 28/05/2012**

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-07:00	590	200	35	355
	07:00-08:00	550	200	35	315
	08:00-17:00	350	200	35	115
	17:00-24:00	550	200	35	315
NER→ER	00:00-07:00	570	0	100	470
	07:00-08:00	570	0	100	470
	08:00-17:00	110	0	100	10
	17:00-24:00	570	0	100	470

**3. For 29/05/2012**

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-08:00	550	200	35	315
	08:00-17:00	350	200	35	115
	17:00-24:00	550	200	35	315
NER→ER	00:00-08:00	570	0	100	470
	08:00-17:00	110	0	100	10
	17:00-24:00	570	0	100	470