## Frequency Response Characteristic Calculation for All India based on NLDC SCADA Data

**EVENT**:

At 10:08 Hrs Dated 26th-April-2022, As reported due to blackout at 400kV Padghe (MH), Load loss of around 3110 MW occured in Western Regon in Mumbai,MMR,Nasik,Ahmednagar area.In the event load loss of around 1694 MW occurred due to tripping of 5 No. of 400/220kV ICTs at 400kV Padghe(MH) and 1263 MW load relief came from various LTS (Load Trimming Scheme) operation.Accordingly Load loss figure of 1694 MW is considered in FRC Calculation.

S No	Particulars	Dimension	NR	ER	WR	NER	SR
1	Actual Net Interchange before the Event (10:08:20)	MW	4741	-4264	-5563	94	4542
2	Actual Net Interchange after the Event (10:10:00)	MW	5284	-4184	-6449	123.0	4828
3	Change in Net Interchange (2 - 1)	MW	543	80	-886	29.0	286
4	Generation Loss (+) / Load Throw off (-) during the Event	MW	0	0	-1694	0	0
5	Control Area Response (3 - 4)	MW	543	80	808	29	286
6	Frequency before the Event	HZ	49.93	49.93	49.93	49.93	49.93
7	Frequency after the Event	HZ	50.05	50.05	50.05	50.05	50.05
8	Change in Frequency (7 - 6)	HZ	0.117	0.117	0.117	0.117	0.117
9	Frequency Response Characteristic (5 / 8)	MW/Hz	4641	686	6905	248	2444
10	Net System Demand met before the Event	MW	53437	21513	62114	1990	52564
11	Internal Generation before the Event (10 - 1)	MW	48696	25777	67677	1896	48022
12	Ideal load response assuming 4% per Hz (0.04*Row 10)	MW/Hz	2137	861	2485	80	2103
13	Ideal generator response assuming 5% droop40% per Hz (40% of Row 11)	MW/Hz	19478	10311	27071	758	19209
14	Composite ideal response (12 + 13)	MW/Hz	21616	11171	29555	838	21311
15	Percentage ideal response	%	21.5%	6.1%	23.4%	29.6%	11.5%

(\*) - Data may be constant/suspected during the event Note: +ve exchange=> import ; (-)ve exchange => export

Total Change in (MW)	1694	
FRC for NEWS GRID (dp/df) MW/Hz	14479	
Power Number (net change in MW/maximum change in frequency )	11219	