

**National Load Despatch Centre**  
**Import of Haryana Transfer Capability for September 2021**

Issue Date: 28-08-2021

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st September 2021 to 30th September 2021	00-24	8500	600	7900	4300	3600		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV ICTs at Deepalpur and Kurukshetra(PG)						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages