

# National Load Despatch Centre

## Transfer Capability for Import of DD & DNH for September 2016

Issue Date: 26/8/2016

Issue Time: 1745 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 16 to 30th Sep 16	00-24	1300	0	1300	LTA and MTOA as per ex-pp schedule		100	Revised due to commissioning of 220KV Kala-Kharadpada D/C.

<b>Limiting Constraints</b>	Low voltages in 220KV Vapi and Karadpada
-----------------------------	--

**National Load Despatch Centre**  
**Transfer Capability for Import of DD & DNH for September 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	26/8/2016	Whole Month	Revised due to commissioning of 220KV Kala-Kharadpada D/C.