

National Load Despatch Centre
Transfer Capability for Import of DD for May 2021

Issue Date: 28th January 2020

Issue Time: 1800 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 31st May 2021	00-24	620	10	610	LTA and MTOA as per ex-pp schedule			

Limiting Constraints	N-1 contingency of 220 kV Magarwada(PG)-Magarwada(DD) line will overload the other circuit
-----------------------------	--

**National Load Despatch Centre
Transfer Capability for Import of DD for May 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected