

National Load Despatch Centre
Import of Punjab Transfer Capability for August 2020

Issue Date: 22nd June 2020

Issue Time: 1200 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2020 to 31st August 2020	00-24	7200	600	6600	4515	2085		Revision in TTC/ATC due to the following:- a) Implementation of SPS at 400/220 kV Rajpura ICTs b) Generation restriction at TSPL
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for August 2020

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	22nd June 2020	Whole Month	Revision in TTC/ATC due to the following:- a) Implementation of SPS at 400/220 kV Rajpura ICTs b) Generation restriction at TSPL