

National Load Despatch Centre
Import of Punjab Transfer Capability for August 2021

Issue Date: 29th July 2021

Issue Time: 1330 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2021 to 15th August 2021	00-08	8300	600	7700	4860	2840	900	1) Forced outage of Talwandi Saboo Unit-1. 2) Implementation of SPS at Nakodar. 3) Punjab SLDC has informed that working hours of general industries in Nakodar, Gobindgarh(Rajpura) and Ludhiana area is 9am-6pm. Therefore, loading is lower in these area during night hours. 4) Punjab SLDC to ensure loading below N-1 contingency limit at 400/220kV Moga ICTs during high solar generation.
	08-18	7900	600	7300	4860	2440	500	
	18-24	8300	600	7700	4860	2840	900	
16th August 2021 to 31st August 2021	00-24	7400	600	6800	4860	1940		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for August 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	29th July 2021	Whole Month	1) Forced outage of Talwandi Saboo Unit-1. 2) Implementation of SPS at Nakodar. 3) Punjab SLDC has informed that working hours of general industries in Nakodar, Gobindgarh(Rajpura) and Ludhiana area is 9am-6pm. Therefore, loading is lower in these area during night hours. 4) Punjab SLDC to ensure loading below N-1 contingency limit at 400/220kV Moga ICTs during high solar generation.