

National Load Despatch Centre
Import of Punjab Transfer Capability for August 2021

Issue Date: 07th August 2021

Issue Time: 1415 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2021 to 7th August 2021	00-08	8300	600	7700	4360	3340		
	08-18	7900	600	7300	4360	2940		
	18-24	8300	600	7700	4360	3340		
8th August 2021	00-08	8600	600	8000	4360	3640	300	TTC-ATC revised in view of outage of Unit#2 at TSPL
	08-18	7900	600	7300	4360	2940	0	
	18-24	8600	600	8000	4360	3640	300	
9th August 2021 to 15th August 2021	00-08	8300	600	7700	4360	3340		
	08-18	7900	600	7300	4360	2940		
	18-24	8300	600	7700	4360	3340		
16th August 2021 to 31st August 2021	00-24	7400	600	6800	4860	1940		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre
Import of Punjab Transfer Capability for August 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	29th July 2021	1st August 2021 to 15th August 2021	1) Forced outage of Talwandi Saboo Unit-1. 2) Implementation of SPS at Nakodar. 3) Punjab SLDC has informed that working hours of general industries in Nakodar, Gobindgarh(Rajpura) and Ludhiana area is 9am-6pm. Therefore, loading is lower in these area during night hours. 4) Punjab SLDC to ensure loading below N-1 contingency limit at 400/220kV Moga ICTs during high solar generation.
2	30th July 2021	1st August 2021 to 15th August 2021	On request of Punjab, STOA margin revised by 500 MW due to under utilization of LTA
3	7th August 2021	8th August 2021	TTC-ATC revised in view of outage of Unit#2 at TSPL