

National Load Despatch Centre
Import of Punjab Transfer Capability for December 2021

Issue Date: 29th November 2021

Issue Time: 1700 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|--|
| 1st December 2021 to 31st December 2021 | 00-08 | 8000 | 600 | 7400 | 4860 | 2540 | 600 | Due to 400kV bus split work completion at Moga. Variation in loadings during day and night in Rajpura, Ludhiana and Nakodar areas. |
| | 08-18 | 7700 | 600 | 7100 | 4860 | 2240 | 300 | |
| | 18-24 | 8000 | 600 | 7400 | 4860 | 2540 | 600 | |
| Limiting Constraints | | 1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for December 2021

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---|--|
| 1 | 29th November 2021 | 1st December 2021 to 31st December 2021 | Due to 400kV bus split work completion at Moga. Variation in loadings during day and night in Rajpura, Ludhiana and Nakodar areas. |