

National Load Despatch Centre
Import of Punjab Transfer Capability for December 2021

Issue Date: 21st December 2021

Issue Time: 1330 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2021 to 21st December 2021	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
22nd December 2021 to 23rd December	00-08	8300	600	7700	4860	2840	300	Due to tripping of talwandi sabo unit 2.
	08-18	8100	600	7500	4860	2640	400	
	18-24	8300	600	7700	4860	2840	300	
24th December 2021 to 31st December 2021	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for December 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	29th November 2021	1st December 2021 to 31st December 2021	Due to 400kV bus split work completion at Moga. Variation in loadings during day and night in Rajpura, Ludhiana and Nakodar areas.
2	21st December	22nd December to 23rd December	Due to tripping of talwandi sabo unit 2.