National Load Despatch Centre Import of Punjab Transfer Capability for December 2025

Issue Date: -17th l	Issue Time: 15:00				Revision No. 1				
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)		Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments	
1st Dec 2025 to 31st Dec 2025	00-24	10600	500	10100	5497	4603	300	400/220kV ICT Capacity augmentation at Nakodar and Patran	
Limiting Constraints		 N-1 contigency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar, Muktsar. Loading close to N-1 contingency limits of 400/220kV Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 							

Import of Punjab Transfer Capability

Issue Date: -	Date ofPeriod ofRevisionRevision		Reason for Revision		
	17th Feb 25	19th Feb Onwords	400/220kV ICT Capacity augmentation at Nakodar and Patran		