

National Load Despatch Centre
Import of Punjab Transfer Capability for February 2020

Issue Date: 28th October 2019

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 20 to 29th February 20	00-24	7000	600	6400	4580	1820		
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for February 2020

Revision No	Date of Revision	Period of Revision	Reason for Revision