

National Load Despatch Centre
Import of Punjab Transfer Capability for February 2021

Issue Date: 31st December 2020

Issue Time: 1800 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2021 to 28th February 2021	00-24	7000	600	6400	3469	2931		LTA/MTOA revised by 1064MW on request of Punjab SLDC due to non utilisation
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for February 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	31-Dec-20	Whole month	LTA/MTOA revised by 1064MW on request of Punjab SLDC due to non utilisation.