## **National Load Despatch Centre**

## Import of Punjab Transfer Capability for February 2022

Issue Date: 07th February 2021 Issue Time: 1300 hrs Revision No. 3

| Date   | Time Period in<br>IST (hrs)   | Total<br>Transfer<br>Capability<br>(TTC) | Reliability<br>Margin | Available<br>Transfer<br>Capability<br>(ATC) | Long Term<br>Access (LTA)/<br>Medium Term<br>Open Access<br>(MTOA) # | Margin<br>Available for<br>Short Term<br>Open Access<br>(STOA) | Changes in TTC<br>w.r.t. Last<br>Revision | Comments  |
|--|---|--|-----------------------|--|--|--|---|---|
| 1st February 2022 to<br>06th February 2022     | 00-08   | 8000                                     | 600                   | 7400   | 4860   | 2540   |   |   |
|  | 08-18   | 7700                                     | 600                   | 7100   | 4860   | 2240   |   |   |
|  | 18-24   | 8000                                     | 600                   | 7400   | 4860   | 2540   |   |   |
| 07th February 2022                             | 00-08   | 8300                                     | 600                   | 7700   | 4860   | 2840   |   |   |
|  | 08-18   | 8100                                     | 600                   | 7500   | 4860   | 2640   |   |   |
|  | 18-24   | 8300                                     | 600                   | 7700   | 4860   | 2840   |   |   |
| 08th February 2022                             | 00-08   | 8300                                     | 600                   | 7700   | 4860   | 2840   | 300                                       | TTC/ATC revised due to tripping of<br>Talwandi Sabo Unit 2. |
|  | 08-18   | 8100                                     | 600                   | 7500   | 4860   | 2640   | 400                                       |   |
|  | 18-24   | 8300                                     | 600                   | 7700   | 4860   | 2840   | 300                                       |   |
| 09th February 2022<br>to 28th February<br>2022 | 00-08   | 8000                                     | 600                   | 7400   | 4860   | 2540   |   |   |
|  | 08-18   | 7700                                     | 600                   | 7100   | 4860   | 2240   |   |   |
|  | 18-24   | 8000                                     | 600                   | 7400   | 4860   | 2540   |   |   |
| Limiting Constra                               | 1. N-1 contigency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana.<br>2. 220 kV underlying network at Ludhiana and Amritsar |  |                       |  |  |  |   |   |

## National Load Despatch Centre Import of Punjab Transfer Capability for February 2022

| Revision<br>No | Date of<br>Revision | Period of<br>Revision | Reason for Revision                                    |  |  |  |
|----------------|---------------------|-----------------------|--|--|--|--|
|                |                     | 1st February          | Due to 400kV bus split work completion at Moga.        |  |  |  |
| 1              | 28th January 2021   | 2022 to 28th          | Variation in loadings during day and night in Rajpura, |  |  |  |
|                |                     | February 2022         | Ludhiana and Nakodar areas.                            |  |  |  |
| 2              | 06th February       | 7th February          | TTC/ATC revised due to tripping of Talwandi Sabo       |  |  |  |
|                | 2021                | 2021                  | Unit 2.  |  |  |  |
| 3              | 7th Folomour 2021   | 8th February          | TTC/ATC revised due to tripping of Talwandi Sabo       |  |  |  |
|                | 7th February 2021   | 2021                  | Unit 2.  |  |  |  |