

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for February 2025**

Issue Date: 28th February 2024

Issue Time: 15:00

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2025 to 28th February 2025	00-08	9500	500	9000	5497	3503		
	08-18	9500	500	9000	5497	3503		
	18-24	9500	500	9000	5497	3503		
<b>Limiting Constraints</b>		<ol style="list-style-type: none"> <li>1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar.</li> <li>2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs</li> <li>3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar</li> <li>4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC.</li> <li>5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.</li> </ol>						

**Import of Punjab Transfer Capability for February 2025**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>