

**National Load Despatch Centre**  
**Import Capability of Punjab for Feb 2025**

Issue Date: -17th February 2025

Issue Time: 1600

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2025 to 18th February 2025	00-24	10300	500	9800	5497	4303	0	
19th February 2025 to 28th February 2025	00-24	10600	500	10100	5497	4603	300	400/220kV ICT Capacity augmentation at Nakodar and Patran
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICT at Rajpura, Ludhiana, Jalandhar, Muksar Loading close to N-1 contingency limits of 400/220kV Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						
<b>Reason</b>		<b>400/220kV ICT Capacity augmentation at Nakodar and Patran</b>						

**Import of Punjab Transfer Capability for Feb 2025**

<b>Issue Date: 17-02-2025</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
	17-Feb-25	19th Feb 25 Onwards	400/220kV ICT Capacity augmentation at Nakodar and Patran