

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for January 2016**

Issue Date: 28/09/2015

Issue Time: 1315 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st November 15 to 30th November 15	00-24	6200	500	5700	4033	1667		
<b>Limiting Constraints</b>		(N-1) contingency of 400/220 kV ICT at Amritsar, Dhuri and 220 kV underlying network at Ludhiana						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for January 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor Affected</b>