

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2018

Issue Date: 28/03/2018

Issue Time: 1500 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st July 18 to 31st July 18 | 00-24 | 6700 | 600 | 6100 | 5596 | 504 | | |
| Limiting Constraints | | 1. (N-1) contingency of 500 MVA ICT at Ludhiana (PG), Amritsar (PG) and N-1 contingency of 315 MVA ICT at Makhu will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2018

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |