

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2020

Issue Date: 28th April 2020

Issue Time: 1800 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|--|
| 1st July 2020 to 31st July 2020 | 00-24 | 7000 | 600 | 6400 | 4515 | 1885 | | Revision in STOA margin due to change in allocation. |
| Limiting Constraints | | 1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2020

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|--|
| 1 | 28th April 2020 | Whole Month | Revision in STOA margin due to change in allocation. |