

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Issue Date: 12th April 2021

Issue Time: 1500 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2021 to 31st July 2021	00-24	7400	600	6800	4860	1940	400	1. Revision in TTC/ATC for summer/monsoon 2021 (Paddy season) 2. Revision in STOA margin due to increase in LTA/MTOA by 345 MW
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	12th April 2021	Whole month	1. Revision in TTC/ATC for summer/monsoon 2021 (Paddy season) 2. Revision in STOA margin due to increase in LTA/MTOA by 345 MW