

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Issue Date: 06th July 2021

Issue Time: 17:00 hrs

Revision No. 11

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2021	00-24	7900	600	7300	4360	2940		
2nd July 2021	00-24	7900	600	7300	4360	2940		
3rd July 2021	00-24	7900	600	7300	4360	2940		
4th July 2021	00-24	7900	600	7300	4360	2940		
5th July 2021	00-09	8400	600	7800	4360	3440		
	09-17	7900	600	7300	4360	2940		
	17-24	8400	600	7800	4360	3440		
6th July 2021	00-08	8400	600	7800	4360	3440		
	08-09	8400	600	7800	4360	3440		
	09-18	7900	600	7300	4360	2940		
	18-24	8100	600	7500	4360	3140		
7th July 2021	00-08	8400	600	7800	4360	3440	300	Revised TTC/ATC due to forced outage of Talwandi Saboo Unit # 1
	08-09	8400	600	7800	4360	3440	500	
	09-18	7900	600	7300	4360	2940		
	18-24	8100	600	7500	4360	3140		
8th July 2021 to 15th July 2021	00-08	8100	600	7500	4360	3140		
	08-18	7900	600	7300	4360	2940		
	18-24	8100	600	7500	4360	3140		
16th July 2021 to 31st July 2021	00-08	8100	600	7500	4860	2640		
	08-18	7900	600	7300	4860	2440		
	18-24	8100	600	7500	4860	2640		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar. 3. High loading of 220kV lines such as Rajpura-Gobindgarh, Dhuri-Sunam, Jalandhar-Kartarpur, Muksar-Malout etc.						

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
2	4th May 2021	1st July to 31st July 2021	Revised TTC/ATC due to planned outage of Talwandi Saboo Unit # 3
3	29th June 2021	1st July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
4	30th June 2021	2nd July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
5	2nd July 2021	3rd July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
6	2nd July 2021	4th July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
7	3rd July 2021	5th July 2021 to 15th July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
8	4th July 2021	5th July 2021	Revised TTC/ATC due to forced outage of Talwandi Saboo Unit # 1
9	4th July 2021	6th July 2021 to 31st July 2021	Revised TTC/ATC due to the reasons mentioned in TTC sheet.
10	5th July 2021	6th July 2021	Revised TTC/ATC due to forced outage of Talwandi Saboo Unit # 1
11	6th July 2021	7th July 2021	Revised TTC/ATC due to forced outage of Talwandi Saboo Unit # 1