

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Issue Date: 04th July 2021

Issue Time: 11:30 hrs

Revision No. 8

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|----------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|---|
| 1st July 2021 | 00-24 | 7900 | 600 | 7300 | 4360 | 2940 | | |
| 2nd July 2021 | 00-24 | 7900 | 600 | 7300 | 4360 | 2940 | | |
| 3rd July 2021 | 00-24 | 7900 | 600 | 7300 | 4360 | 2940 | | |
| 4th July 2021 | 00-24 | 7900 | 600 | 7300 | 4360 | 2940 | | |
| 5th July 2021 | 00-09 | 8400 | 600 | 7800 | 4360 | 3440 | 500 | Revised TTC/ATC due to forced outage of Talwandi Saboo Unit # 1 |
| | 09-17 | 7900 | 600 | 7300 | 4360 | 2940 | | |
| | 17-24 | 8400 | 600 | 7800 | 4360 | 3440 | 500 | |
| 6th July 2021 to 15th July 2021 | 00-24 | 7900 | 600 | 7300 | 4360 | 2940 | | |
| 16th July 2021 to 31st July 2021 | 00-24 | 7900 | 600 | 7300 | 4860 | 2440 | | |
| Limiting Constraints | | 1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------------|--|
| 2 | 4th May 2021 | 1st July to 31st July 2021 | Revised TTC/ATC due to planned outage of Talwandi Saboo Unit # 3 |
| 3 | 29th June 2021 | 1st July 2021 | On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab |
| 4 | 30th June 2021 | 2nd July 2021 | On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab |
| 5 | 2nd July 2021 | 3rd July 2021 | On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab |
| 6 | 2nd July 2021 | 4th July 2021 | On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab |
| 7 | 3rd July 2021 | 5th July 2021 to 15th July 2021 | On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab |
| 8 | 4th July 2021 | 5th July 2021 | Revised TTC/ATC due to forced outage of Talwandi Saboo Unit # 1 |