

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2025

Issue Date: -17th February 2025

Issue Time: 15:00

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2025 to 31st July 2025	00-24	10600	500	10100	5497	4603	300	400/220kV ICT Capacity augmentation at Nakodar and Patran
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar, Muktsar. 2. Loading close to N-1 contingency limits of 400/220kV Malerkotla and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

Import of Punjab Transfer Capability

Issue Date:	Date of Revision	Period of Revision	Reason for Revision
	17th Feb 25	19th Feb Onwards	400/220kV ICT Capacity augmentation at Nakodar and Patran