

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2018**

Issue Date: 01/05/2018

Issue Time: 1600 hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 18 to 30th June 18	00-24	7000	600	6400	4680	1720	300	Revised TTC considering generation scenario specified by Punjab and revised STOA margin considering auxiliary consumption of ISGS plants
<b>Limiting Constraints</b>		1. (N-1) contingency of 500 MVA ICT at Ludhiana (PG), Amritsar (PG) and N-1 contingency of 315 MVA ICT at Makhu will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2018**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	27th March 2018	Whole Month	Revised STOA margin due to 200 MW LTA from Bokaro TPS-A of DVC to PSPCL
2	2nd April 2018	Whole Month	Revised STOA margin due to 200 MW LTA from Karcham Wangtoo HEP to PSPCL
3	3rd April 2018	Whole Month	Revised STOA margin considering 85% availability of ISGS plants
4	1st May 2018	Whole Month	Revised TTC considering generation scenario specified by Punjab and revised STOA margin considering auxiliary consumption of ISGS plants