

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2019

Issue Date: 14th June 2019

Issue Time: 1700 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 19 to 15th June 19	00-24	6800	600	6200	4580	1620		
16th June 19 to 30th June 19	00-24	7000	600	6400	4580	1820	200	Revised TTC due to restriction of Talwandi Saboo Generation to 1620 MW (instead of 1830 MW given earlier) and Punjab own generation to 5805 MW (instead of 6035 MW earlier)
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muksar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2019

ate: 14th June 2019

Issue Time: 1700 hrs

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	21st May'19	1st June 19 to 30th June 19	a) Change in Load - Generation Balance (LGBR) in Punjab. b) Change in operationalized LTA/MTOA from 4680 MW to 4580 MW.
2	14th June'19	16th June 19 to 30th June 19	Revised TTC due to restriction of Talwandi Saboo Generation to 1620 MW (instead of 1830 MW given earlier) and Punjab own generation to 5805 MW (instead of 6035 MW earlier)

Revision No. 2