

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2020

Issue Date: 23rd June 2020

Issue Time: 1300 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2020 to 22nd June 2020	00-24	7000	600	6400	4515	1885		
23rd June 2020	00-24	7600	600	7000	4515	2485		
24th June 2020	00-24	7200	600	6600	4515	2085	-400	Revision in TTC/ATC due to the revival of one unit of Rajpura TPS
25th June 2020 to 30th June 2020	00-24	7200	600	6600	4515	2085		
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Nakodar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre
Import of Punjab Transfer Capability for June 2020**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	28th April 2020	Whole Month	Revision in STOA margin due to change in allocation.
2	22nd June 2020	23rd June 2020 to 24th June 2020	Revision in TTC/ATC due to the following:- a) Implementation of SPS at 400/220 kV Rajpura ICTs b) Outage of one unit of Rajpura TPS
		25th June 2020 to 30th June 2020	Revision in TTC/ATC due to the following:- a) Implementation of SPS at 400/220 kV Rajpura ICTs b) Generation restriction at TSPL
3	23rd June 2020	24th June 2020	Revision in TTC/ATC due to the revival of one unit of Rajpura TPS