

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2021**

Issue Date: 12th April 2021

Issue Time: 1500 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2021 to 30th June 2021	00-24	7400	600	6800	4860	1940	400	1. Revision in TTC/ATC for summer/monsoon 2021 (Paddy season) 2. Revision in STOA margin due to increase in LTA/MTOA by 345 MW
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2021**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	12th April 2021	Whole month	1. Revision in TTC/ATC for summer/monsoon 2021 (Paddy season) 2. Revision in STOA margin due to increase in LTA/MTOA by 345 MW