

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2024**

Issue Date: 31-05-2024

Issue Time: 17:00

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024	00-24	10000	500	9500	5497	4003		
2nd June 2024 to 6th June 2024	00-24	10400	500	9900	5497	4403	400	Outage of Talwandi - Sabo Unit - 1
7th June 2024 to 30th June 2024	00-24	10000	500	9500	5497	4003		
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Muksar. 2. Loading close to N-1 contingency limits of 400/220KV Patran, Malerkotla, Dhanansu and Jalandhar ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

## Import of Punjab Transfer Capability for June 2024

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	20-May-24	1st June 2024 to 30st June 2024 and 3rd June 2024 to 30st June 2024	Change in load generation scenario (high internal generation in Punjab). Commissioning of 400/220kV Dhanansu ICT-1 and forced outage of LehraMohabbat Unit 2
2	31-05-2024	2nd June 2024 - 6th June 2024	Outage of Talwandi - Sabo Unit - 1