

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for March 2022**

Issue Date: 15th March 2022

Issue Time: 1145 hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2022 to 13th March 2022	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
14th March 2022	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
15th March 2022	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
16th March 2022	00-08	8300	600	7700	4860	2840	300	Due to outage of Talwandi Sabo unit 3
	08-18	8100	600	7500	4860	2640	400	
	18-24	8300	600	7700	4860	2840	300	
17th March 2022 to 31st March 2022	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre  
Import of Punjab Transfer Capability for March 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	28th February 2022	1st March 2022 to 31st March 2022	Due to 400kV bus split work completion at Moga. Variation in loadings during day and night in Rajpura, Ludhiana and Nakodar areas.
2	13th March 2022	14th March 2022	Due to outage of Talwandi Sabo unit 3
3	14th March 2022	15th March 2022	Due to outage of Talwandi Sabo unit 3
4	15th March 2022	16th March 2022	Due to outage of Talwandi Sabo unit 3