## National Load Despatch Centre Import of Punjab Transfer Capability for March'26

Issue Date: -26th March 2025 Issue Time: 15:00 Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	* *	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st to 31st March'26	00-24	10600	500	10100	5497	4603		
Limiting Constra	N-1 contigency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar.     Loading close to N-1 contingency limits of 400/220kV Malerkotla, Moga and Patiala ICTs     3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar     4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC.     5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.							

## Import of Punjab Transfer Capability for March'26

Issue Date:	Date of Revision	Period of Revision	Reason for Revision			