

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2016

Issue Date: 27/5/2016

Issue Time: 1730 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 16 to 28th May 16	00-24	6200	500	5700	4033	1667	0	
29th May 16 to 31st May 16	00-24	6400	500	5900	4102	1798	200	Revised considering high/full generation in Punjab and change in LTA/MTOA allocation
Limiting Constraints		1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana						

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	27/5/2016	29/5/2016 to 31/5/2016	Revised considering high/full generation in Punjab and change in LTA/MTOA allocation	Import of Punjab