

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2017

Issue Date: 28/1/2017

Issue Time: 1745 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st May 17 to 31st May 17 | 00-24 | 6400 | 500 | 5900 | 4102 | 1798 | | |
| Limiting Constraints | | 1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2017

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |