

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2017

Issue Date: 18/5/2017

Issue Time: 1500 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 17 to 18st May 17	00-24	6400	500	5900	4102	1798		
19th May 17 to 31st May 17	00-24	7100	600	6500	4261	2239	700	Revised considering outage of Talwandi Saboo generating plant
Limiting Constraints		1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. Constraint in 220 kV underlying network at Ludhiana, Amritsar						

**National Load Despatch Centre
Import of Punjab Transfer Capability for May 2017**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	18th May 2017	19th May 2017 to 31st May 2017	Revised considering outage of Talwandi Saboo generating plant