

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2022

Issue Date: 28 May 2022

Issue Time: 1400 Hrs

Revision No. 6

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 10th May 2022	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
11th May 2022	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
12th May 2022 to 21st May 2022	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
22nd May 2022 to 26th May 2022	00-08	8200	500	7700	4860	2840		
	08-18	8200	500	7700	4860	2840		
	18-24	8200	500	7700	4860	2840		
27th May 2022	00-08	8500	500	8000	4860	3140		
	08-18	8500	500	8000	4860	3140		
	18-24	8500	500	8000	4860	3140		
28th May 2022	00-08	8500	500	8000	4860	3140		
	08-18	8500	500	8000	4860	3140		
	18-24	8500	500	8000	4860	3140		
29th May 2022	00-02	8200	500	7700	4860	2840	-300	Due to revival of Talwandi Sabi unit 3
	02-08	8200	500	7700	4860	2840		
	08-18	8200	500	7700	4860	2840		
	18-24	8200	500	7700	4860	2840		
30th May 2022 to 31st May 2022	00-08	8200	500	7700	4860	2840		
	08-18	8200	500	7700	4860	2840		
	18-24	8200	500	7700	4860	2840		
Limiting Constraints		1. N-1 contingency of 400/220 KV ICTs at Rajpura, Nakodar, Ludhiana. SPS installed at Rajpura and Nakodar. 2. 220 kV underlying network at Ludhiana and Amritsar 3. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 4. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

**National Load Despatch Centre
Import of Punjab Transfer Capability for May 2022**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	28.04.2022	1st May 2022 to 10th May 2022	Overhauling of Talwandi Saboo Unit -2
		1st May 2022 to 31st May 2022	Bus split at 400kV Moga
2	09.05.2022	11th May 2022	Overhauling of Talwandi Saboo Unit -2
3	20.05.2022	22nd May 2022 to 31st May 2022	Augmentation of 315MVA ICT by 500MVA ICT at Ludhiana(PG)
4	26.05.2022	27th May 2022	Due to tripping of Talwandi Sabo Unit - 3
5	27.05.2022	28th May 2022 to 29th May 2022	Due to tripping of Talwandi Sabo Unit - 3
6	28.05.2022	29th May 2022	Due to revival of Talwandi Sabo Unit - 3