

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for November 2015**

Issue Date: 30/07/2015

Issue Time: 1130 hrs

Revision No. 1

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st November 15 to 30th November 15	00-24	6200	500	5700	4033	1667	500	Revised considering new transmission network and generation commissioned in Punjab control area
<b>Limiting Constraints</b>		n-1 contingency of 400/220 kV ICT at Amritsar, Dhuri and 220 kV underlying network at Ludhiana						

## National Load Despatch Centre

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor Affected</b>
1	30-07-2015	01-11-2015 to 30-11-2015	Revised considering new transmission network and generation commissioned in Punjab control area	Import of Punjab