

National Load Despatch Centre
Import of Punjab Transfer Capability for October 2016

Issue Date: 28/6/2016

Issue Time: 1300 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-----------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st Oct 16 to 31st Oct 16 | 00-24 | 6400 | 500 | 5900 | 4102 | 1798 | | |
| Limiting Constraints | | 1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for October 2016

| Revision No | Date of Revision | Period of Revision | Reason for Revision | Corridor Affected |
|--------------------|-------------------------|---------------------------|----------------------------|--------------------------|
| | | | | |