

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2016

Issue Date: 28/5/2016

Issue Time: 1530 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 16 to 30th Sep 16	00-24	6200	500	5700	4102	1598		
Limiting Constraints		1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana						

**National Load Despatch Centre
Import of Punjab Transfer Capability for September 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected