

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for September 2017**

Issue Date: 26/5/2017

Issue Time: 1700 hrs

Revision No. 0

| Date                                  | Time Period in IST (hrs) | Total Transfer Capability (TTC)   | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st September 17 to 30th September 17 | 00-24                    | 6500  | 600                | 5900                                | 4261   | 1639   |                                     |          |
| <b>Limiting Constraints</b>           |                          | 1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs.<br>2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana |                    |                                     |  |  |                                     |          |

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for September 2017**

| <b>Revision No</b> | <b>Date of Revision</b> | <b>Period of Revision</b> | <b>Reason for Revision</b> |
|--------------------|-------------------------|---------------------------|----------------------------|
|                    |                         |                           |                            |