

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2017

Issue Date: 04/7/2017

Issue Time: 1100 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 17 to 30th September 17	00-24	6700	600	6100	4261	1839		Revised considering revival of Talwandi Saboo and Goindwal generating plants
Limiting Constraints		1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana						

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	04th July 2017	Whole month]	Revised considering revival of Talwandi Saboo and Goindwal generating plants