

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2019

Issue Date: 14th June 2019

Issue Time: 1700 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 19 to 30th September 19	00-24	7000	600	6400	4580	1820	200	Revised TTC due to restriction of Talwandi Saboo Generation to 1620 MW (instead of 1830 MW given earlier) and Punjab own generation to 5805 MW (instead of 6035 MW earlier)
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	14th June'19	16th June 19 to 30th June 19	Revised TTC due to restriction of Talwandi Saboo Generation to 1620 MW (instead of 1830 MW given earlier) and Punjab own generation to 5805 MW (instead of 6035 MW earlier)