

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2022

Issue Date: 26 May 2022

Issue Time: 1500 Hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st Sep 2022 to 30th Sep 2022 | 00-08 | 8200 | 500 | 7700 | 4860 | 2840 | 0 | |
| | 08-18 | 8200 | 500 | 7700 | 4860 | 2840 | 0 | |
| | 18-24 | 8200 | 500 | 7700 | 4860 | 2840 | 0 | |
| Limiting Constraints | | <ol style="list-style-type: none"> 1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. SPS installed at Rajpura and Nakodar. 2. 220 kV underlying network at Ludhiana and Amritsar 3. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 4. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit. | | | | | | |

National Load Despatch Centre
Import of Punjab Transfer Capability for September 2022

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |