## **National Load Despatch Centre**

## Import of Jharkhand Transfer Capability for January 2022

Issue Date: 26th December 2021 Issue Time: 1600 hrs Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 20221 to 31st January 2022	00-24	1551	47	1504	1248	256		TOTAL GENERATION 340 MW,total load 1840 MW
Limiting Constraints		Limited by LGI	3R					