

National Load Despatch Centre
Import of Jharkhand Transfer Capability for April 2021

Issue Date: 26th March 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2021 to 30th April 2021	00-24	1570	53	1517	841.63	675		
Limiting Constraints		132 kV Maithon-Jamtara line						

National Load Despatch Centre			
Import of Jharkhand Transfer Capability for April 2021			
Revision No	Date of	Period of	Reason for Revision