

**National Load Despatch Centre**  
**Import of Jharkhand Transfer Capability for August 2021**

Issue Date: 26th July 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2021 to 31st August 2021	00-24	1470	52	1418	842	576		TOTAL GENERATION 478 MW, total load 1896 MW
<b>Limiting Constraints</b>		132 kV Maithon-Jamtara and 132 kV Adityapur-Rajkarswan						