

National Load Despatch Centre
Import of Jharkhand Transfer Capability for February 2021

Issue Date: 28th January 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2021 to 28th Feb 2021	00-24	1536	49	1487	841.54	645		
Limiting Constraints		132 kV Maithon-Jamtara line						

National Load Despatch Centre			
Import of Jharkhand Transfer Capability for Feb 2021			
Revision No	Date of Revision	Period of Revision	Reason for Revision

Note : These are indicative figures to encourage self regulation among states.